



# 中国国家强制性产品认证证书

证书编号：2018010304109915

委托人名称、地址

ABB AB, Control Products  
Motorgrand 20, 72161 Vasteras, Sweden

生产者（制造商）名称、地址

ABB AB, Control Products  
Motorgrand 20, 72161 Vasteras, Sweden

生产企业名称、地址

ABB AB, Control Products  
Motorgrand 20, 72161 Vasteras, Sweden

产品名称和系列、规格、型号

软起动器

PSE210-600-70-1, PSE250-600-70-1, PSE300-600-70-1, PSE370-600-70-1; 详情见附件

产品标准和技术要求

GB/T 14048.6-2016

上述产品符合强制性产品认证实施规则 CNCA-C03-02:2014 的要求，  
特发此证。

发证日期：2018 年 08 月 31 日      有效期至：2023 年 08 月 31 日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书的相关信息可通过国家认监委网站 [www.cnca.gov.cn](http://www.cnca.gov.cn) 查询



主任：



## 中国质量认证中心



# CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

CERTIFICATE NO.: 2018010304109915

## NAME AND ADDRESS OF THE APPLICANT

ABB AB, Control Products  
Motorgrand 20, 72161 Vasteras, Sweden

## NAME AND ADDRESS OF THE MANUFACTURER

ABB AB, Control Products  
Motorgrand 20, 72161 Vasteras, Sweden

## NAME AND ADDRESS OF THE FACTORY

ABB AB, Control Products  
Motorgrand 20, 72161 Vasteras, Sweden

## PRODUCT NAME, MODEL AND SPECIFICATION

Soft Starter  
PSE210-600-70-1, PSE250-600-70-1, PSE300-600-70-1, PSE370-600-70-1; See the appendix

## THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB/T 14048.6-2016

This is to certify that the above mentioned product(s) complies with the requirements of implementation rules for compulsory certification(REFNO.CNCA-C03-02:2014).

Valid from: Aug.31,2018

Valid until: Aug.31,2023

The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

The certificate information is available through CNCA's website: [www.cnca.gov.cn](http://www.cnca.gov.cn)



President:

Wang Kejiao



## CHINA QUALITY CERTIFICATION CENTRE



# 中国国家强制性产品认证证书

附录

第 1 页 共 2 页

证书编号: 2018010304109915

纸号: 2030766

PSE210-600-70-1, PSE250-600-70-1, PSE300-600-70-1, PSE370-600-70-1

额定绝缘电压(Ui): 600V;

约定发热电流(Ith): PSE210-600-70-1:210A, PSE250-600-70-1:250A,

PSE300-600-70-1:300A, PSE370-600-70-1:370A;

额定工作电压(Ue): 208-500V;

额定工作电流(Ie): PSE210-600-70-1:210A, PSE250-600-70-1:250A,

PSE300-600-70-1:300A, PSE370-600-70-1:370A;

额定功率(Pe):

Type	Ie (A)	Power(kW)		
		220-240 V	380-400 V	500V
PSE210-600-70-1	210	59	110	132
PSE250-600-70-1	250	75	132	160
PSE 00-600-70-1	300	90	160	200
PSE370-600-70-1	370	110	200	257

使用类别: AC-53a;

极数: 3P

注: 此附录与证书同时使用时有效。



主任:



## 中国质量认证中心



# 中国国家强制性产品认证证书

附 录

第 2 页 共 2 页

证书编号: 2018010304109915

纸 号: 2030766

型号的解释:

PSE 370 - 600 - 70 - 1

1    2    3    4    5

1 = Softstarter, name of series

2 = Current rating, Ie: 210A, 250A, 300A, 370A

3 = Operational voltage Ue:208-500VAC

4 = Control supply voltage, Us: 70 = 100 - 250VAC

5 = Design code

Type	Ie (A)	Power(KW)		
		220-240V	380-400V	500V
PSE210-600-70-1	210	59	110	132
PSE250-600-70-1	250	75	132	160
PSE300-600-70-1	300	90	160	200
PSE370-600-70-1	370	110	200	257

注: 此附录与证书同时使用时有效。



主 任:



## 中国质量认证中心