



国家防爆

Electrical Apparatus for Explosive Atmospheres

CERTIFICATE OF CONFORMITY

Cert. No.: CNEx19.2392X

Manufacturer Eaton MEDC Limited
 Unit B, Sutton Parkway, Oddcroft Lane, Sutton-in-Ashfield, NG175FB, UK

Name of Product Loudspeaker

Type of Product DB4BE G

Marking Ex de IIC T*Gb (Ta -50°C to +*°C)

Drawing No. 399-101, 419-108

The drawings, technical documents and the samples are verified and certified according to standard(s) for safety as below:

GB 3836.1-2010 Explosive atmospheres - Part 1: Equipment - General requirements
 GB 3836.2-2010 Explosive atmospheres - Part 2: Equipment protection by flameproof enclosure "d"
 GB 3836.3-2010 Explosive atmospheres - Part 3: Equipment protection by increased safety "e"

Note

1. Temperature range: $-50^{\circ}\text{C} \leq T_a \leq +*^{\circ}\text{C}$, see Annex
2. This certificate is only valid in combination with the related Annex(2 pages in total)
3. Please read and understand the special conditions for safe use as stated in the Annex to this certificate

Valid Date From May 24, 2019 to May 23, 2024

Issue Date May 24, 2019

Director



CHINA NATIONAL QUALITY SUPERVISION AND TEST CENTRE FOR EXPLOSION PROTECTED ELECTRICAL PRODUCTS

Address: No.20 North Zhongjing Rd, Nanyang, Henan(473008), P.R.China

Tel: 0377-63258564 Fax: 0377-63208175 Http://www.china-ex.com

Note: This certificate is only valid for the products which identify with the sample(s) tested and verified. Holder(s) of this certificate have the responsibility to ensure the products complying with relevant standard(s).

登陆网站 输入数码 查询真伪 2018 6321 7480 7328 查询方式: www.china-ex.com



国家防爆

Electrical Apparatus for Explosive Atmospheres

CERTIFICATE OF CONFORMITY

Cert. No.: CNEx19.2392X

Page 1 of 2

This product has been certified by Baseefa, under certificate number Baseefa13ATEX0232X/5, dated on 2019-02-05.

Product Description:

The DB4BE G Loudspeaker may be rated up to 100V at either 8W, 15W or 25W and comprises a cylindrical body and two covers all moulded in Glass Reinforced Polyester. The front cover is an irregular shape which when fitted forms a chamber for the speaker driver assembly and is permanently sealed/filled with a potting compound. In the front of this cover is a fine stainless steel mesh pressed metal wire element to facilitate sound transmission.

The circular rear cover closes an Ex e terminal enclosure and is secured by three M5 stainless steel screws. The screws may be profiled to be retained within the rear cover during assembly/dis-assembly. The Ex e chamber houses a certified terminal block of either 4, 6 or 8 (2x4) Ex e connection.

The base of this enclosure then forms the cover of the flameproof chamber and with integral cables passing through a potted bushing arrangement. The terminal enclosure is fixed with six M5x20mm long stainless steel socket head screws of grade A2-70 minimum.

The screws may be profiled to be retained within the rear cover during assembly/dis-assembly. The flameproof Chamber houses an assembly of a transformer and a control/terminal PCB.

Up to two M20 or M25 cable entries are provided in the side of the enclosure to accommodate suitably certified cable entry devices.

Issue Date May 24, 2019

Director



**CHINA NATIONAL QUALITY SUPERVISION AND TEST CENTRE
FOR EXPLOSION PROTECTED ELECTRICAL PRODUCTS**

Address: No.20 North Zhongjing Rd, Nanyang, Henan(473008), P.R.China

Tel: 0377-63258564 Fax: 0377-63208175 [Http://www.china-ex.com](http://www.china-ex.com)

Note: This certificate is only valid for the products which identify with the sample(s) tested and verified. Holder(s) of this certificate have the responsibility to ensure the products complying with relevant standard(s).



国家防爆

Electrical Apparatus for Explosive Atmospheres

CERTIFICATE OF CONFORMITY

Cert. No.: CNEx19.2392X

Page 2 of 2

A plastic horn assembly (with either a long or short flare) is fitted externally to the front, and along the sides, of the enclosure, together with a mounting bracket.

The equipment may be marked with one or multiple combinations, as below:

Model	Power	Temperature marking
DB4BE G	8W	T4(T _{amb} =-50 C ≤ Ta ≤ +85°C)
		T5(T _{amb} =-50 C ≤ Ta ≤ +55°C)
		T6(T _{amb} =-50 C ≤ Ta ≤ +40°C)
	15W	T3(T _{amb} =-50 C ≤ Ta ≤ +85°C)
		T4(T _{amb} =-50 C ≤ Ta ≤ +70°C)
		T5(T _{amb} =-50 C ≤ Ta ≤ +40°C)
	25W	T4(T _{amb} =-50 C ≤ Ta ≤ +70°C)
		T5(T _{amb} =-50 C ≤ Ta ≤ +40°C)

国家防爆

Issue Date May 24, 2019

Director



CHINA NATIONAL QUALITY SUPERVISION AND TEST CENTRE FOR EXPLOSION PROTECTED ELECTRICAL PRODUCTS

Address: No.20 North Zhongjing Rd, Nanyang, Henan(473008), P.R.China

Tel: 0377-63258564 Fax: 0377-63208175 Http://www.china-ex.com

Note: This certificate is only valid for the products which identify with the sample(s) tested and verified. Holder(s) of this certificate have the responsibility to ensure the products complying with relevant standard(s).