

CERTIFICATE OF COMPLIANCE

Certificate Number 20150303-E203310
Report Reference E203310-20150108
Issue Date 2015-MARCH-03

Issued to: MEDC
Unit B
Sutton Parkway, Oddicroft Lane
Sutton-In-Ashfield
NG17 5FB UNITED KINGDOM

**This is to certify that
representative samples of**

AUDIBLE-SIGNAL APPLIANCES, FIRE ALARM, FOR USE IN
ZONE CLASSIFIED

USL - Audible signal device, Fire Alarm,
Model DB3B G, for use in Class I, Zone 1, AEx d IIC hazardous
locations.
Model DB3B GD, for use in Class I, Zone 1, AEx d IIC; Zone 21,
AEx tb IIIC hazardous locations.

CNL - Audible signal device, Fire Alarm,
Model DB3B G, for use in Class I, Zone 1, Ex d IIC Gb
hazardous locations.
Model DB3B GD, for use in Class I, Zone 1, Ex d IIC Gb; Class II,
Div. 1, Groups E, F and G; Class III, Div. 1 hazardous locations.
(See Addendum Page for Additional Information.)

Have been investigated by UL in accordance with the
Standard(s) indicated on this Certificate.

Standard(s) for Safety: (See Addendum Page for Standards for Safety)

Additional Information: See the UL Online Certifications Directory at
www.ul.com/database for additional information

Only those products bearing the UL Certification Mark should be considered as being covered by UL's
Certification and Follow-Up Service.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Assistant Chief Engineer, Global Inspection and Field Services

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please
contact a local UL Customer Service Representative at www.ul.com/contactus



CERTIFICATE OF COMPLIANCE

Certificate Number 20150303-E203310
Report Reference E203310-20150108
Issue Date 2015-MARCH-03

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

Additional Information:

Additional Information for Marking

Hazardous location designation as given in "representative samples of".

The EPLs Gb and Db are optional for the US.

Model DB3B G may also be marked for use in Class I, Div. 2, Groups A, B, C and D

Models DB3B GD may also be marked for use in Class I, Div. 2, Groups A, B, C and D; Class II, Div. 2, Groups F & G; Class III, Div. 1 Hazardous Locations.

Standards for Safety:

UL 60079-0, Explosive atmospheres – Part 0: Equipment – General requirements


UL 60079-1, Explosive Atmospheres – Part 1: Equipment Protection by Flameproof Enclosures “d”

ANSI/ISA-60079-31-2009, Explosive Atmospheres – Part 31: Equipment Dust Ignition Protection by Enclosure “t”

CAN/CSA-C22.2 No. 60079-0:11, Explosive atmospheres — Part 0: Equipment — General requirements

CAN/CSA-C22.2 No. 60079-1:11, Explosive atmospheres — Part 1: Equipment protection by flameproof enclosures “d”

CAN/CSA-C22.2 No. 60079-31:12, Explosive atmospheres — Part 31: Equipment Dust Ignition Protection by Enclosure “t”



Bruce Mahrenholz, Assistant Chief Engineer, Global Inspection and Field Services

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at www.ul.com/contactus

