

## Certificate of Product Approval

Certificate Number: 1120a

Issue: 04

### Eaton MEDC Ltd

Unit B, Sutton Parkway  
Oddicroft Lane  
Sutton-in-Ashfield  
NG17 5FB  
United Kingdom



is certified by BRE Global Ltd. and is authorised to use the LPCB mark in association with the product(s) listed in this certificate and appendix having complied with the requirement(s) of the standards as detailed below:

#### Products

##### Alarm Warning Devices

DB3

DB3B 54W

DB3B 54D

(refer to Appendix for details)

#### Standards

EN 54-3:2001 + A1:2002 + A2:2006

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.

Signed for BRE Global Ltd

P Halligan

Verifier

18 May 2020

Date of Issue

26 June 2013

Date of First Issue



This certificate and appendix remains the property of BRE Global Ltd. and is issued subject to terms and conditions (for details visit [www.redbooklive.com/terms](http://www.redbooklive.com/terms)).

To check the validity of this certificate and appendix please visit [www.redbooklive.com/check](http://www.redbooklive.com/check), scan the QR tag or contact us.

BRE Global Ltd, Watford, WD25 9XX  
T: +44 (0)333 321 8811 E: [enquiries@breglobal.com](mailto:enquiries@breglobal.com)

LPCB is a Registered Trademark of the Building Research Establishment Ltd.



## Appendix to Certificate No: 1120a

Issue: 04

### Eaton MEDC Ltd

Certified Product	Description	LPCB Ref.No.
DB3	<p>Conventional Sounder Type B</p> <p>Note:</p> <ol style="list-style-type: none"> <li>Meets the requirements of EN 54-3:2001 for the following tones: <ul style="list-style-type: none"> <li>- Tone 3 – Sweeping 800/970Hz at 1Hz</li> <li>- Tone 7 – Slow whoop 500-1200Hz in 3.5 seconds / 0.5 secs gap</li> <li>- Tone 8 – Sweep 1200-500Hz at 1Hz</li> <li>- Tone 15 – 554Hz for 100ms / 440Hz for 400ms</li> <li>- Tone 19 – Continuous at 660Hz</li> <li>- Tone 20 – Alt 554 / 440Hz at 1Hz</li> </ul> </li> </ol>	1120a/01
DB3B 54W	<p>Conventional Sounder Type B</p> <p>Note:</p> <ol style="list-style-type: none"> <li>Meets the requirements of EN 54-3:2001 for the following tones: <ul style="list-style-type: none"> <li>- Tone 3 – Sweeping 800/1000Hz at 1Hz</li> <li>- Tone 7 – Slow whoop 500-1200Hz in 3.5 seconds / 0.5 secs gap</li> <li>- Tone 8 – Sweep 1200-500Hz at 1Hz</li> <li>- Tone 15 – 554Hz for 100ms / 440Hz for 400ms</li> <li>- Tone 19 – Continuous at 660Hz</li> <li>- Tone 20 – Alt 554 / 440Hz at 1Hz</li> </ul> </li> </ol>	1120a/02

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.



Signed for BRE Global Ltd

P Halligan

Verifier

18 May 2020

Date of Issue

26 June 2013

Date of First Issue



This certificate and appendix remains the property of BRE Global Ltd. and is issued subject to terms and conditions (for details visit [www.redbooklive.com/terms](http://www.redbooklive.com/terms)).

To check the validity of this certificate and appendix please visit [www.redbooklive.com/check](http://www.redbooklive.com/check), scan the QR tag or contact us.

BRE Global Ltd, Watford, WD25 9XX  
T: +44 (0)333 321 8811 E: [enquiries@breglobal.com](mailto:enquiries@breglobal.com)

LPCB is a Registered Trademark of the Building Research Establishment Ltd.




## Appendix to Certificate No: 1120a

Issue: 04

### Eaton MEDC Ltd

Certified Product	Description	LPCB Ref.No.
DB3B 54D	<p>Conventional Sounder Type B (ATEX)</p> <p>Note:</p> <ol style="list-style-type: none"> <li>Meets the requirements of EN 54-3:2001 for the following tones: <ul style="list-style-type: none"> <li>- Tone 3 – Sweeping 800/1000Hz at 1Hz</li> <li>- Tone 7 – Slow whoop 500-1200Hz in 3.5 seconds / 0.5 secs gap</li> <li>- Tone 8 – Sweep 1200-500Hz at 1Hz</li> <li>- Tone 15 – 554Hz for 100ms / 440Hz for 400ms</li> <li>- Tone 19 – Continuous at 660Hz</li> <li>- Tone 20 – Alt 554 / 440Hz at 1Hz</li> </ul> </li> </ol>	1120a/02

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.



Signed for BRE Global Ltd

P Halligan

Verifier

18 May 2020

Date of Issue

26 June 2013

Date of First Issue



This certificate and appendix remains the property of BRE Global Ltd. and is issued subject to terms and conditions (for details visit [www.redbooklive.com/terms](http://www.redbooklive.com/terms)).

To check the validity of this certificate and appendix please visit [www.redbooklive.com/check](http://www.redbooklive.com/check), scan the QR tag or contact us.

BRE Global Ltd, Watford, WD25 9XX  
T: +44 (0)333 321 8811 E: [enquiries@breglobal.com](mailto:enquiries@breglobal.com)

LPCB is a Registered Trademark of the Building Research Establishment Ltd.


