

Certificate of Test

We hereby declare that the item described below
has been tested by BSI and
complies with the requirements of

BS 5490:1977
for a classification of IP66 and IP67

The full details of the tests and the results are given
in our Report No: 193040 Dated: 3 December 1992
Issue 2


Description of item tested:

One MEDC Break Glass Unit Type BG

Submitted by:

MEDC
Colliery Road
Brookhill Industrial Estate
Pinxton
Nottingham NG16 6JF

Certificate authorized by:



D H Price

Title Manager - Lighting Technology Laboratory

Date 3 December 1992



TESTING

Attention is drawn to the conditions upon which this declaration is issued,
namely:

1. The general and specific conditions of the BSI Test House, Test Leaflet 1
apply in all respects. Copies of this leaflet are available on request.

2. This Declaration applies only to the particular sample tested and to the
specific tests carried out as detailed in the report referred to above.

3. This Declaration does not indicate any measure of Approval, Certification,
Supervision, Control or Surveillance by BSI to this or any related product.

For the Director, BSI Testing, Maylands Avenue, Hemel Hempstead, Herts, HP2 4SQ